


WETC



Power Quality Assessment Zafarana Wind Farm Transformer No. 1 [75 MVA] Installed capacity [54.2 MW]

Conducted By

Eng. Amagd M. El-Hewehy
Eng. El-Sayed M. Mansour

New and Renewable Energy Authority [NREA]
Hurghada Wind Farm

WETC

Power Quality Assessment Zafarana Wind Farm Transformer No. 1 [75 MVA] Installed capacity [54.2 MW]

Conducted By

Eng. Amagd M. El-Hewehy
Eng. El-Sayed M. Mansour

New and Renewable Energy Authority [NREA]
Hurghada Wind Farm

Abstract

The report describes power quality assessment performed on transformer substation at Zafarana wind farm regarding the requirements of the standard specification ISO 9001 / 2000.



Overview for Zafarana wind farm

Contents

Title	Page
1. Preface	5
2. Introduction	6
3. Objectives	7
4. Description of The Site	8
4.1 Zafarana Wind Farm	8
4.2 Zafarana Substation	9
5. Data Acquisition and Analysis	11
5.1 Measurement System	11
5.2 Description of Data Handling Routines	11
5.3 The Measurements	13
6. Measurements Analysis and Results	14
6.1 Bus-Bar Voltage Level	14
6.2 Line Current	20
6.3 Grid Frequency	24
6.4 Voltage Harmonics	26
6.5 Current Harmonics	29
6.6 Consumed Reactive Power	30
6.7 Produced Active Power	33
6.8 Capacity Factor	35
7. Conclusion and Recommendations	37
8. References	38
9. Appendix	39

1. Preface

Reasons for Power Quality Assessment

Power quality is an issue of increasing importance. The main reason for this is the increasing demands from the customers with respect to security and quality of supply in order for them to rely on the public power supply in such a way that they do not have to take special measures to ensure that they can conduct their business without concern about the availability of computers, machines, appliances etc.

The varying of the power output from wind turbines has an impact on both the operation of the power system and on the power quality of the system. This impact increases as the level of penetration increases.

The influence on power quality is mainly on the level and fluctuations of voltage and frequency, the stability of voltage and frequency should not be degraded significantly, as the controllers of systems are required to be able to prevent instability. Furthermore, the shape of the voltage should not be degraded by the inclusion of wind power in the system. If wind turbines or storage systems applying power electronics are included in the system, it should be ensured that the distortion of the voltage is within required limits.

The voltage level at the point of connection of the wind turbine to the grid will depend on the output from the wind turbines and on the consumer load. Situations where the voltage becomes high due to a high wind power production and a low consumer load will quite often occur. Design should limit maximum voltage to acceptable levels. Normally, nominal voltage $\pm 10\%$ as instantaneous value or $\pm 5\%$ as 10-minute average value.

Another important aspect is the power fluctuations. The power fluctuations create fluctuations in the voltage and they impose fluctuations to the grid. The voltage fluctuations have to be low to avoid disturbances e.g. in the light intensity. The power fluctuations do not only depend on the amount of installed wind power capacity, but also on whether the wind farm consists of a few large wind turbines or correspondingly more, but smaller wind turbines. The relative power fluctuation level basically is decreasing as the number of wind turbines is increasing and as the power output from the wind turbines is increasing.

2. Introduction

This wind farm measurements and studies program deals with Power Quality Assessment, the measurements for the study of power quality were carried out at Zafarana wind farm and have been approximately one month from 16/12/2005 to 15/01/2006.

This study should primarily be seen as an initiation and illustration of possibilities for activities and studies regarding wind farms at Zafarana, the main task of this study is to evaluate the wind farm performance and electrical properties, as well as the wind farm impact on power quality.

The installation of equipments has been accomplished with technical support and assist from protection and resident engineers at Zafarana substation.

- **Shaaban Ali Atwa**
- **Ehab El-Sayed Hassan**
- **Abdel-Fattah Helmy**

The CMS engineers at Zafarana wind farm have been checked the measurement system and data files, as well as they participated in installation of equipments, and the required data concerning wind speed, errors list during the measurement period had been compiled and reported by them.

- **Akmal El-Hewehy**
- **Mohamed Hader**

The analysis of measurements and printout were carried out at Hurghada WETC by:

- **Amgad El-Hewehy**
- **Sayed Mansour**

3. Objectives

The power quality is most often described in terms of voltage stability, frequency stability and phase balance. The frequency of larger power systems is normally very stable and therefore no problem. At autonomous grids where for example diesel generators are used, wind turbines may cause frequency variations.

Since wind turbine generators represent balanced three-phase sources, they will actually improve the phase balance of the grid when they are connected. Voltage stability can be subdivided into slow voltage variations, voltage dips, flicker, transient and harmonic voltage distortion.

The objective of Power Quality Assessment task is to:

- Illustrate the wind farm impact on power quality in terms of reactive consumption, voltage and frequency deviations.
- Analyze the measurements taken and relate the results obtained to international standards and theoretical calculations.

4. Description of The Site

4.1 Zafarana Wind Farm

Zafarana is situated along the coast of Suez Gulf, 250 km north of Hurghada and 110 km south of Suez, the wind farm (total area approx. 156 km², length of 20 km and width of 8 km, annual average wind speed about 9.4 m/s) located 10 km north of Zafarana town towards Suez city. Figure (1) is an overview map of the Suez Gulf.




Figure 1

Zafarana wind farm presently consists of:

- Nordex wind turbines [(D1 & KFW1), 63 MW] with total capacity of 105 X 600 kW (N43 - 600 kW, 3 blades, stall regulation), the wind turbine is connected to a 50 Hz, 22 kV medium voltage system by a separate transformer of (800 kVA, 0.69/22 kV).
- Vestas wind turbines [(D2 & KFW2 & KFW3), 77 MW] with total capacity of 117 X 660 kW (V47 - 660 kW, 3 blades, pitch control), the wind turbine is connected to a 50 Hz, 22 kV medium voltage system by a separate transformer of (800 kVA, 0.69/22 kV), Figure (2) is an overview for part of zafarana wind farm.

4.2 Zafarana Substation

Zafarana wind farm has been linked to the national grid via a transformer substation located few kilometers north of the site; substation has two stationary transformers and mobile one. The substation has many incoming and outgoing coupling points, as shown in Figure (3).




Figure 3

The substation presently consists of two transformers of 75 MVA, 220 kV for each (TR.1 of 54.2 MW and TR. 2 of 64.9 MW installed capacity), and mobile substation (25 KVA - 21.1 MW).

Each wind turbine is connected to a 50 Hz, 22 kV medium voltage system by a separate transformer of 800 kVA, 0.69/22 kV.

The turbines and its feeders connected to transformer No. 1 are shown in figure (4) (schematic diagram of Zafarana Substation, Transformer No. 1), [Appendix 9, Table (1)].




Figure 4

5. Data Acquisition and Analysis

5.1 Measurement System

The power analyzing system consists of a Voltech PM300 power analyzer, an Olivetti ECHOS 120 laptop PC, and a data logging program called PM300.EXE developed in the programming language Quick Basic 4.5 by Risø National Laboratory. The Voltech PM300 power analyzer performs the actual power measurements, whereas the Basic program PM300.EXE running on the Olivetti laptop computer controls the power analyzer and logs data from it.

The laptop PC running the program PM300.EXE was applied to control the power analyzer and to store data in the hard disk of the PC. The power analyzer was set-up to give total and fundamental values of the three phase active and reactive power, voltage and currents as well as the fundamental frequency, the total harmonic voltage distortion, the odd voltage harmonics up to 11th and the total harmonic current distortion, the sampling rate for storing data to the hard disk was set to 10 second, the measurement continued from 16/12/2005 to 15/01/2006.

The logged raw data are stored in ASCII format on files (Time series) named with 8 digits [(00000000.txt), (name)(year)(month)(day).txt], [Appendix 9, Table (2)]

Voltech PM300 Power Analyzer

The main specifications:

Connection	: three-phase Voltage	Bandwidth	: DC to 250 kHz
Current accuracy	: 0.2 %	Current range (direct)	: 20 A rms (200 A peak)
Watt accuracy	: 0.4 %	Voltage range	: 1000 V peak

The power analyzer has a front panel from which it can be controlled manually and a display to show the measured values however, it is not able to store data.

Laptop CPU

The main specifications:

Processor	: 120 MHz Pentium	Memory	: 16 MB RAM
Screen	: SVGA Color Screen (600x800)	CD-ROM	: 6X Speed
		HD	: 1.2 GB

5.2 Description of Data Handling Routines

Basic program PM300.EXE

The Basic software program sets up the power analyzer and logs the measurements, the communication between the laptop computer and the power analyzer is based on RS232. Basic has been chosen as programming language because a simple starter program in Basic is given in the PM300 user manual for RS232 communication (Ref 5).

The first line in the set-up file is the name of the configuration file (Zaf.CFG), the configuration file is an ASCII file, which enables configuration of the PM300 before the data logging starts, the parameters that can be controlled are wiring, current and voltage scaling, range selection etc.

The second line in the input file is the name of the selection file (Zaf.SEL), this file is also an ASCII file. It determines which channels are logged (channel 1, 2, 3, sum, and possibly neutral) and which parameters are logged (power, reactive power, voltage, frequency, current, etc).

The third line in the set-up file is the name of an ASCII output file. As example, Zb060110.txt has been selected. The head of the output file contains copies of the set-up file, the configuration file, and the selection file. Moreover, after setting the specified configuration, the PM300.EXE program gets all configuration codes from the power analyzer and copies them to the output files. This information is useful if the communication between the laptop PC and the power analyzer has failed. The remainder (and main part) of the output file is the logged data in columns with the time as the first column.

The sixth parameter in the set-up file is the sampling time. The PM300 does not specify how fast the sampling time can be, but our experience showed that it should be more than 3 seconds. The minimum sampling time depend on the specified set-up, for instance if specific time consuming calculations such as harmonics have been selected.

The last parameter is the number of measurement channels. This parameter can-in simple cases-be calculated according to the specifications in the selection file using the table (Page 64) in the RS232 manual. If this number is too small, the Basic program will make confusion in the output data file, and if it is too large, it will stop, waiting for data from the PM300.

The set-up file

The Basic program PM300.EXE runs from DOS with a single parameter: the set-up file name. The set-up file is an ASCII file. For the power quality measurements described in this report, the set-up file Zaf.sup has been used.

The fourth parameter in the set-up file is the baud rate, this parameter must be the same in the input file as set manually on the PM300, because no communication is possible when the baud rate is conflicting.

The fifth parameter in the set-up file is the measurement time. In the example, it is 360000 second corresponding to 100 hours. This high value has been selected to ensure that the data logging is not interrupted by the program. When the user of the program wants to stop the data logging, the Break key can always be used, which will not be sent. An easy way to determine the number of measurement channels is to specify a very high value, and then run PM300.EXE. Then the program will stop after the first sample of data is send from the power analyzer. The program writes data both to the output file and to the screen. Therefore, the number of channels can be counted either from the screen or from the output file after the program has been interrupted.

Note that parameter 4 to 7 in the set-up file consists of data followed by a comment. The three first parameters, however, have only file names and no comments. Because of the simple reading procedure of the Basic program, this syntax must be followed.

Configuration file

The configuration file specifies the configuration such as wiring, scaling etc. A complete list of the available parameters is given in the RS232 manual for the PM300 (Pages 58-63). The first two columns are data used by the PM300.EXE Basic program to configure the power analyzer. The following text is only for comments to the user. Note that the user must specify a comment, because PM300.EXE reads it from the file.

The frequency source (configuration parameter 14 and 15) can cause problems with keeping a fixed sampling time if the frequency of the current shall be calculated but the current is approximately zero. Therefore, the frequency source has been selected to voltage.

Selection file

The original purpose of the selection file was only to enable the specification of selection commands such as: SEL: SUM and: SEL: WAT as described in the RS232 manual for the PM300 (Pages 64-66). However, the PM300.EXE Basic program has implemented this task simply by sending the contents of the selection file to the Power Analyzer. Consequently, the selection file can also be used to specify other commands than selection commands to the power analyzer. As an example of that, the command: HMX : ODD 11 is added to the configuration file below, specifying odd harmonic orders up to 11 the harmonic [RS232 manual (Page 40)].

Data Analysis files

A software program called PM300sta.EXE developed by Risø were used to generate statistical file (STA, 10-minute Average) [Appendix 9, Table (3)]. from time series file (TXT, 10-sec)

As well as another software program (Consolstanal.EXE, input, listfile) developed by Risø were used for generate two output files, the first is statistical file (the mean value for continuously 10 minute, daily “measurement period”) and the second is diurnal file (the mean value as 10-minute over 24 hour throughout measurement period from midnight to midnight), [Appendix 9, Table (4)].

The data analysis were performed using Microsoft Excel.

5.3 The Measurements

The measurements were carried out at Zafarana substation on 22 kV Bus Bar, the substation has no single feeder with the total output power of the wind farm, thereby a direct measurements of the total output power is not possible. At substation there are two permanent transformer and mobile one, in order to measure the total power, the currents of the three transformers (TR. 1, TR. 2 and mobile one) must be summed simultaneously using summation transformer where it was not available during the measurements period.

According to the situation at zafarana substation, it is decided to achieve the measurements individually on transformer No. 2 and transformer No. 1, thereby the measurement equipments had been connected to the secondary side of the potential transformer (22000/100 V) to measure the voltage, as well as the current measured using current clamps (1 mV: 1 mA) on the secondary side of the existing current transformer (2000:1 A) of transformer No. 1.

6. Measurements Analysis and Results

Key data for Zafarana wind farm measurements

ITEM	DESCRIPTION
Start Date	16/12/2005
Stop Date	15/01/2006
Nominal power	54.2 MW
Max. output power (10-minute average)	46.14 MW
Min. output power (10-minute average)	0.12 MW
Mean. output power (10-minute average)	12.44 MW
Mean PF (10-minute average)	76.1
Mean CF (10-minute average)	22.95
Mean Bus-Bar Voltage (10-minute average)	22.87 kV


6.1 Bus-Bar Voltage

The valid measurement with the power analyzer on 22 kV Bus-Bar give basis for assessing the voltage quality and to analyze the impact of the wind farm on the voltage quality.

Plot (1) is the statistical data of the mean value of the Bus-Bar voltage, the voltage level during the measurement period between 22.25 kV and 23.31 kV, or in other words 22 kV + **5.97 %** and – 1.03 %.

International standard (IEC - Ref 3) specifies that the voltage level should be within $\pm 5 \%$ of its nominal value measured as 10-minute average data or $\pm 10 \%$ of its measured instantaneous values.

From the results obtained, it could be stated that the voltage level when reaches to its minimum value still within the required limit, meanwhile it is out of range when reaches to its maximum value.




Plot 1

Plot (2) is the statistical data as 10-minute average values of the Bus-Bar voltage plotted versus the 10-minute average values of the output active power from the wind turbines.

In this plot, the voltage level decreases for increasing the active power from the wind turbines, as well as the voltage level seems to be extremely high at low power generated from the wind turbines (cloudy points seen in the plot).

The situation is predicted, since the nominal power of the wind turbine connected to transformer no.1 is 54.2 MW, which is significantly high-generated power.



Plot 2

Plot (3) is the statistical data of the three phase voltages as 10-minute average during the measurement period, the limits of the three phase voltages are shown below:

Phase No. 1 varies from 12.62 kV to 13.26 kV, or 12.7 kV + 4.39% and - 0.6 %.


Phase No. 2 varies from 13.26 kV to 13.87 kV, or 12.7 kV + **9.21 %** and -4.38 %.

Phase No. 3 varies from 12.62 kV to 13.26 kV, or 12.7 kV + 4.39% and - 0.6 %.

The international standard specifies that the voltage level should be within $\pm 5 \%$ of its nominal value measured as 10-minute average data.

From the results obtained, it could be stated that the maximum and minimum values of phase No. 2 and phase No. 3 respectively, are critically out of range.


note: The amplitude of the resulting voltage, drop or rise will depend on the impedance of the feeder between the wind turbine and the substation. The stability of the grid will be sensitive to the ratio of X/R where (X) is the source impedance's reactance and (R) is the source impedance's resistance.



Plot 3

Plot (4) is the absolute value of the frequency distribution as 10-minute average value of the Bus-Bar voltage, there are two different situations are clearly observable in the plot, the first is the distribution is not symmetrical around the nominal value (22 kV) (Z_0).

The second is that two peaks are noticed at 22.1 kV and 22.2 kV, as well as the voltage range is quite narrow due to the wind farm connected to a large network. The voltage varies almost from 21.3 kV (Z_1) to 22.7 kV (Z_2) during the measurement period.




Plot 4

Hint: for a given set of values and a given set of bins (intervals), a frequency distribution counts how many of the values occur in each interval.

Plot (5) is the voltage change relative to the initial (nominal) value “22 kV” from one 10-minute value to the next, the majority of the relative voltage changes are between +2.2 % and -2.6 % as magnitude (bin).


The plot shows that voltage varies in a small range and very few values above +3 % occur. No significant peaks are noticed in the plot, as well as the distribution is not symmetrical around Z_0 (when $V_{mean} = V_{initial}$).



Plot 5


$$V_{relative} = \left[\frac{V_{mean} - V_{initial}}{V_{initial}} \right] * 100$$

Plot (6) is the diurnal pattern for the mean, maximum and minimum value of the Bus-Bar voltage, the plot is the typical value of the Bus-Bar voltage profile, since the plot is the average value throughout the measurement period.




Plot 6

Plot (7) is the diurnal pattern of the three phase voltages as 10-minute average, it is clearly seen in the plot that phase No. 1 and phase No. 3 are slightly lower than phase No. 2.




Plot 7

Plot (8) is the diurnal pattern of the grid voltage and grid frequency, the plot shows that the grid frequency is almost constant independent of the Bus-Bar voltage level.




Plot 8

Plot (9) illustrates the diurnal pattern of the Bus-Bar voltage and active power, the plot shows that the voltage varies reversely to the active power. Assuming a fairly relation between the voltage and the output power, it is obviously seen in the plot that the maximum value of active power (50.9 MW) corresponds to minimum value of voltage (21.5 kV) as 10-minute average value.



Plot 9


Plot (10) is the diurnal pattern of the Bus-Bar voltage and mean wind speed, the plot indicates that the voltage values seem to vary reversely to the wind speed values. The plot corresponds with voltage-power correlation as shown in Plot (9).



Plot 10

6.2 Line Current


Plot (11) is the statistical data of the line current as 10-minute average during the measurement period.



Plot 11

Plot (12) is the diurnal pattern of mean, maximum and minimum values of line current. The plot is the typical value of the line current profile as the plot is the average of the measurement period.


The maximum value looks constant; meanwhile, the mean and minimum values look fluctuated very much.



Plot 12


Plot (13) is the statistical data of a correlation between the output active power and line current as 10-minute average value, the plot shows that the power varies proportionally to the line current; however, there is a situation where, a small deviation has been occurred.

The raw data (Time series as 10-sec.) has been investigated carefully, and it is concluded that the current reading of phase No.1 was not match (lower than) with the other two phases, only on day 7/9/2005. The reason for this still unknown.




Plot 13

Plot (14) illustrates the diurnal pattern of active power and line current as 10-minute average, the plot shows that the output power varies proportionally to the line current.




Plot 14

Plot (15) is the diurnal pattern of three phase line currents as mean value. The plot is the typical values of the three-phase currents profile as the plot is the average throughout the measurement period



Plot 15


Plot (16) is the statistical data of the load factor as 10-minute average value; the load factor is 0.96 as an average value as shown in the plot.




Plot 16

Plot (17), (18) and (19) illustrate the ratio between max, min and mean values of the statistical data as 10-minute average value respectively.

The ratio looks constant even though the two peaks and drops seen in the plots. The interpretation for the two peaks and drops are related to low power production at low wind speed.



Plot 17



Plot 18





Fig 19

6.3 Grid Frequency

Plot (20) is the statistical data of the grid frequency profile as 10-minute average values. It is seen from the plot that the grid frequency is very stable independent of other grid parameters; the average value is 49.96 Hz during the measurement period.


The plot shows that the frequency lays within a narrow band between 49.86 Hz and 50.13 Hz that comply with the international standards (50 Hz ± 1 %).



Plot 20

Plot (21) is the statistical data of a correlation between the grid frequency and active power, the grid frequency remains constant independent of the produced power from the wind turbines.


It is noticed also that the cloudy points in the plot is quit wide at high output power from the farm, however, the changes in the frequency still in a very small range.



Plot 21


Plot (22) is the absolute change of the frequency distribution as 10-minute average values of the grid frequency, it is obviously seen in the plot that, the frequency is well controlled with only small deviations from the 50 Hz nominal setting, these small deviations are slightly above 50 Hz.

The grid frequency is quite symmetrical and triangular around 49.98 Hz, varying from 49.92 Hz to 50.03 Hz.




Plot 22

Plot (23) is the diurnal pattern of the mean, maximum and minimum values of the grid frequency, the plot emphasis the result obtained in Plot (22).



Plot 23

Plot (24) is the statistical data of mean, maximum and minimum values of grid frequency as 10-minute average value.




Plot 24

6.4 Voltage Harmonics


Plot (25) is the statistical data as 10-minutes average value of the Total Harmonic Distortion (THD) of the Bus-Bar voltage.

It can be seen from the plot that the measured THD within the measurement period are between 0.3 % and 3.11 %, which comply with the international standards (Voltage THD should less than 5% measured as 10-minute average) for supply voltage characteristics.




Plot 25

Plot (26) is the statistical data of a correlation between voltage THD and active power as 10-minute average value, the maximum value (3.11%) of THD occurred at 0.5 MW, indicating no particular relation between the output active power and the voltage THD, but the voltage THD follows the daily load pattern.




Plot 26

Plot (27) is the voltage THD in case of high and low wind speed, the plot emphasizes the fact that the wind turbines are not responsible for causing any significant harmonic distortion, in particular, the wind turbines at the site are fixed-speed with induction generator (without a power electronic converter).




Plot 27




Plot (28) is the diurnal pattern of the mean and maximum values of the total harmonic distortion of the Bus-Bar voltage.

The plot is the typical voltage THD profile since the plot is the average value throughout the measurement period.



Plot 28

Plot (29) illustrate the absolute value of the frequency distribution of the voltage THD, the plot does not show any particular features except for a low mean value of THD.




Plot 29

6.5 Current Harmonics

Plot (30) is the statistical data as 10-minute average value of the line current THD, it is clearly seen from the plot that there is a peak of 70 % of THD, and it is clarified that the peak corresponds with low wind speed during the measurement period.


However, the other situations in the plot show very low line THD which comply with the IEC.



Plot 30

Plot (31) is the diurnal pattern of the mean and maximum values of the line current THD, the plot shows that the line current THD follows load pattern except for the situation of low wind speed.


The plot corresponds with the diurnal line current plot (Plot 12), i.e. maximum current THD occurred at minimum line current.



Plot 31

6.6 Consumed Reactive Power


Plot (32) is the statistical data as 10-minute average values of the consumed reactive power by the wind turbines. The mean value of the consumed reactive power is 17.22 kVAR during the measurement period.



Plot 32

Plot (33) is the diurnal pattern of the mean, maximum and minimum values of the consumed reactive power.


The plot is the typical consumed reactive power profile since the graph is the average values of the measurements period.



Plot 33


Plot (34) is the statistical data of the reactive power consumption as a function of active power production, the plot shows that the reactive power varies proportionally to the active power, even though the values are scattered when the active power is high.

The vague correlation between active and reactive power on one day still needs for an interpretation, the consumed reactive power on that day looks higher than the active power.



Plot 34


Plot (35) is the diurnal pattern of the consumed reactive power and the active power as mean value, the plot shows that the reactive power varies proportionally to the active power.



Plot 35


Plot (36) is the statistical data of a correlation between power factor and output power, the power factor looks reasonable at a value above 0.90 due to the two types of the wind turbines (Nordex – Vestas) are regulated by 200 kVAr and 250 kVAr of capacitor banks respectively.

The power factor “ $\cos(\varphi)$ ” has its maximum value of about 0.99 around 4.41 MW output power from the wind turbines.



Plot 36


Plot (37) is the diurnal pattern of the power factor and active power as mean value, the plot shows that the power factor decreases for increasing the active power.



Plot 37

6.7 Produced Active Power


Plot (38) is the statistical data as 10-minute average of the output active power from the wind turbines, from the plot it is seen that the average value of the output active power is 42.12 MW during the measurement period, the plot corresponds with the line current plot (Plot 11).



Plot 38


Plot (39) is the absolute value of the frequency distribution of statistical data as 10–minute average of the output active power from the wind turbines.

The distribution has a tail towards low production as well as the output active power varies from Zero MW to 55.06 MW as mean value and the majority of high active power data represent more than 60 % of the full data.




Plot 39

Plot (40) is the diurnal pattern of the mean, maximum and minimum of the active power value. The maximum value looks constant meanwhile the minimum value is somewhat does not show any particular features. The plot corresponds with the diurnal line current profile plot (Plot 12).



Plot 40

Plot (41) is the diurnal pattern of the active power and wind speed as mean value, it is observed that the wind speed is rather high during the measurement period, [Appendix 9, Table (5)].




Plot 41

6.8 Capacity Factor

Plot (43) is the statistical data of the capacity factor (CF) as 10-minute average values, the average capacity factor during the measurement period is 64.94 %, which is quite high.


The capacity factor is determined according to the following equation:-

$$CF = \left[\frac{Power_{act}}{Power_{theo}} \right] * 100$$



Plot 43

Plot (44) is the absolute value of the frequency distribution of statistical data as 10–minute average of the capacity factor, the capacity factor varies from zero to 85 % as mean value, and the majority of high values of CF represent more than 60 % of the full data.



Plot 44

7. Conclusion and Recommendations

- ◆ During the measurement period the voltage level at Zafarana substation was between 21.06 kV and 22.73 kV, or in other words 22 kV +3.3 % and -4.27 %, International standard IEC (Ref 3) specifies that the voltage level should be within ± 5 % of its nominal value measured as 10-minute average data or ± 10 % of its measured instantaneous values. From the results obtained it could be stated that the voltage level when reaches to its maximum value still within the required limit, meanwhile it is critical when reaches to its minimum value.
- ◆ The voltage level at substation (point of connection of the wind turbines to the grid) depends on the output power from the wind turbines.
- ◆ The absolute value of the voltage changes lays in a narrow range and non-symmetrical around the nominal value, considering the wind farm connected to the 220 kV national grid.
- ◆ The maximum value of phase No.2 is 13.40 kV (12.7 kV + 5.50 %) and minimum value of phase No.3 is 11.98 kV (12.7 kV -5.70 %) , the two voltage limits are out of range.
- ◆ In case of adding more wind turbines, a through analysis must be executed, in particular voltage level.
- ◆ During the measurement period, the grid frequency was between 49.86 Hz and 50.13 Hz being within the required limits to comply with international standards on supply voltage characteristics.
- ◆ The load factor (mean / max) is 96 % which is quite reasonable.
- ◆ During the measurement period, the measured total harmonic distortion THD of the voltage on day 7/9/2005 reached to 3.11% being within the required limit to comply with international standards on supply voltage characteristics.
- ◆ The total harmonic distortion in voltage is not due to the output power from the wind turbines, but follows the daily load pattern.
- ◆ No correspondence between harmonic amplitude and overall power output level.
- ◆ Fixed-speed wind turbines do not produce any harmonics; meanwhile variable-speed wind turbines may be produce different amounts and orders of harmonics depending on the type of inverter used.
- ◆ The maximum current THD occurred at minimum line current.
- ◆ The reactive power consumption of the wind farm increases for increasing output power.
- ◆ The maximum value of the power factor is 0.99 at output power 4.41 MW.
- ◆ The average capacity factor of the wind farm is 64.9 % during the measurement period.
- ◆ The majority of high active power data represent more than 60 % of the full data.
- ◆ The average wind speed throughout the measurement period is 12.69 m/s.
- ◆ No measurements were performed regarding power fluctuations, flicker, and transient since this kind of measurements requires specific instruments that were not available.

8. References

1. *Isolated System with Wind Power, Results of Measurements in Egypt.*
Henrik Bindner, Risø National Laboratory, Laila Saleh, Salah Abdel-Hafiez and El-Sayed Mansour, New and Renewable Energy Authority.
2. *Hurghada Wind Energy Center (WETC), Demonstration Wind Farm Studies, Power Quality Assessment.*
Jhon Tande, Poul Sorensen, Risø National Laboratory, Denmark, Mohamed Galal, Usama Naoman, El-Sayed Mansour, Amgad El-Hewehey, Ahmed El-Maghawry and Ibrahim Darweesh, New and Renewable Energy Authority.
3. *Grid Interaction and power Quality of Wind Turbine Generator Systems.*
Ake Larsson, Chalmers University of Technology.
4. *The International Energy Community standard (IEC).*
5. *The PM300 User Manual of RS232*

9. Appendix

Table (1) Wind Turbines and its Feeders connected to TR 1

Project	D 1 F 1			D 1 F 2			D 2 LOT 1			KFW 1 F 3			KFW 2, 3 LOT 3		
Feeders	J 6			J 7			J 8			J 9			J 10		
Number of WTGs	17			17			15			20			18		
WTG capacity (kW)	600			600			660			600			660		
Total capacity (MW)	10.2			10.2			9.9			12.0			11.9		
WTG no.	1	2	3	11	12	13	1	2	3	24	25	26	22	23	24
	4	5	6	14	15	16	4	5	6	27	28	29	25	26	27
	7	8	9	17	18	33	7	8	24	30	31	32	28	29	30
	10	26	27	34	35	36	25	26	27	33	34	35	31	32	33
	28	29	30	37	38	39	28	29	30	36	37	38	34	35	36
	31	32		40	41					39	40	41	37	38	39
										42	43				

Table 1

Table (2) The Output Text File (Time series) from PM300.EXE program

```

DATE: 08-17-2005
SETUP FILE ZAF.SUP:
  ZAF.CFG
  ZAF.SEL
ZA050817.txt
19200  BAUD RATE
1000000  MEASUREMENT TIME (SEC)
10  SAMPLE TIME (SEC)
25  NUMBER OF MEASUREMENTS (CHANNELS) CORRESP TO SPECIF IN SELECTION FILE
CONFIGURATION FILE ZAF.CFG:
1 4  FAST OPERATING
2 0  3 PHASE 4 WIRE
4 1  FIXED AVERAGING
5 1  AVERAGING DEPTH
6 1  EXTERINAL CURRENT SHUNT
10 0  FIXED VOLTAGE RANGING
11 0  FIXED CURRENT RANGING
14 1  MANUAL FREQ SOURCE
15 1  FREQ SOURCE IS VOLTAGE
19 1  VOLTAGE HARM ENAB
23 11  HARMONIC ORDER
24 1  ODD HARMONICS
38 220  VOLTAGE SCALING
39 25  CURRENT SCALING
SELECTION FILE ZAF.SEL:
:SEL:CLR
:SEL:CH1;;SEL:CH2;;SEL:CH3;;SEL:SUM;
:SEL:WAT;;SEL:VAR;;SEL:VLT;;SEL:AMP;;SEL:VDF;;SEL:ADF
:SEL:FRQ
14:17:39  14181000  15964000  15417000  45560000  7039000  6407000  6505000  20020000  12342  12757  12276  21580  1282.8  1348.4  1363  1331.4  49.94  49.94  49.94  0.72  0.69  0.74  1.25  1.31  1.26
14:17:49  14449000  16247000  15659000  46360000  7210000  6605000  6682000  20560000  12312  12740  12253  21540  1311.5  1376.6  1389.4  1359.2  49.88  49.88  49.88  0.51  0.86  1.08  0  1.15  0.98
14:17:59  14391000  16020000  15457000  45870000  6907000  6332000  6418000  19714000  12388  12774  12290  21620  1288.6  1348.5  1361.8  1333  49.94  49.94  49.94  0.48  0.72  0.98  1.28  1.04  0.85
14:18:09  14287000  15846000  15343000  45480000  6915000  6365000  6452000  19783000  12427  12747  12273  21620  1277.2  1339.7  1356.2  1324.4  50.05  50.05  50.05  0.64  0.55  0.62  1.03  0.98  0.99
14:18:19  14267000  15967000  15404000  45640000  6988000  6413000  6498000  19959000  12398  12762  12276  21610  1281.4  1348.4  1361.9  1330.5  49.94  49.94  49.94  0.63  0.58  0.61  1.09  1.02  0.95
14:18:29  14459000  16130000  15557000  46150000  7055000  6479000  6559000  20150000  12390  12750  12267  21600  1298.5  1363.3  1376.3  1346  49.95  49.95  49.95  0  0.49  0.69  0  0  0.98
14:18:39  14378000  16183000  15609000  46170000  7063000  6431000  6512000  20080000  12340  12754  12271  21570  1298.2  1365.4  1378.2  1347.3  49.94  49.94  49.94  0  0  0.57  0  0  0
    
```

Table 2

Table (3) The Output Statistical File (10-minute average) generated by using PM300STA.EXE program

```

DATE: 08-17-2005
SETUP FILE ZAF.SUP:
ZAF.CFG
ZAF.SEL
ZA050817.txt
19200 BAUD RATE
1000000 MEASUREMENT TIME (SEC)
10 SAMPLE TIME (SEC)
25 NUMBER OF MEASUREMENTS (CHANNELS) CORRESP TO SPECIF IN SELECTION FILE
CONFIGURATION FILE ZAF.CFG:
1 4 FAST OPERATING
2 0 3 PHASE 4 WIRE
4 1 FIXED AVERAGING
5 1 AVERAGING DEPTH
6 1 EXTERNAL CURRENT SHUNT
10 0 FIXED VOLTAGE RANGING
11 0 FIXED CURRENT RANGING
14 1 MANUAL FREQ SOURCE
15 1 FREQ SOURCE IS VOLTAGE
19 1 VOLTAGE HARM ENAB
23 11 HARMONIC ORDER
24 1 ODD HARMONICS
38 220 VOLTAGE SCALING
39 25 CURRENT SCALING
SELECTION FILE ZAF.SEL:
:SEL:CLR
:SEL:CH1;:SEL:CH2;:SEL:CH3;:SEL:SUM;
:SEL:WAT;:SEL:VAR;:SEL:VLT;:SEL:AMP;:SEL:VDF;:SEL:ADF
:SEL:FREQ
Number of channels 25
141000 19750200 15 14359467 133935 14654000 14173000 16019002 138924 16247000 15703000 15480866 120275 15659000 15221000 45860668 371927 46480000 45100000
142000 19750800 60 14843550 280991 15491000 14271000 16571886 318644 17202000 15945000 16010284 301280 16591000 15393000 47426330 892502 49200000 45700000
143000 19751400 60 14842849 183489 15280000 14454000 16528596 200685 16966000 16113000 15985852 191028 16401000 15637000 47357670 561379 48560000 46200000
144000 19752000 60 14710833 193369 15198000 14343000 16419083 199864 16867000 15966000 15857301 206120 16308000 15455000 46988164 588205 48350000 45870000
145000 19752600 60 14671218 215820 15128000 14175000 16350198 225484 16742000 15783000 15777753 214815 16137000 15275000 46799164 644503 47950000 45320000
150000 19753200 60 14803333 323210 15525000 14147000 16481184 345180 17209000 15802000 15923453 337013 16622000 15260000 47207825 997943 49350000 45210000
141000 19750200 15 6985533.3 94461.3 7210000 6775000 6399333.3 89867.3 6605000 6198000 6468800 85503.9 6682000 6303000 19914534 265796 20560000 19332000
142000 19750800 60 7256652.3 185742 7633000 6922000 6680016 183062 7063000 6355000 6760749.3 176794 7138000 6443000 20757700 545873 21900000 19779000
143000 19751400 60 7104884.3 140054 7392000 6863000 6526850.7 131285 6833000 6296000 6621349.3 128437 6918000 6405000 20312668 399336 21200000 19639000
144000 19752000 60 7228334.4 136180 7457000 6891000 6658749.3 130149 6876000 6352000 6757168.5 129504 6983000 6452000 20703046 393385 21350000 19745000
145000 19752600 60 7143616 194956 7491000 6682000 6559381.3 194982 6927000 6097000 6663400.5 196365 6985000 6211000 20425882 580580 21460000 19050000
150000 19753200 60 7128665.1 233542 7626000 6680000 6553398.9 228801 7014000 6112000 6654483.2 224433 7182000 6223000 20394767 685160 21880000 19083000
141000 19750200 15 12371.87 31.09 12427 12312 12750.47 15.56 12774 12707 12273.67 13.5 12290 12240 21589.33 26.13 21620 21540
142000 19750800 60 12366.42 34.78 12434 12298 12741 15.04 12777 12709 12265.15 9.69 12293 12243 21577 25.6 21620 21520
143000 19751400 60 12376.48 34.92 12441 12317 12747.33 15.29 12784 12719 12274.45 9.54 12301 12255 21591.83 27.62 21660 21540
144000 19752000 60 12355.52 31.7 12413 12295 12732.28 15.76 12766 12700 12256.87 12.64 12280 12225 21560.5 27.3 21620 21500
145000 19752600 60 12355.87 34.39 12414 12286 12722.7 24.96 12769 12648 12251.15 22.21 12293 12177 21552.67 38.01 21630 21440
150000 19753200 60 12375.03 32.58 12443 12320 12742.77 18.19 12775 12707 12269.07 14.43 12294 12241 21585.17 30.04 21650 21530
141000 19750200 15 1290.75 11.93 1311.5 1268.2 1352.91 12.34 1376.6 1324.3 1366.98 11.66 1389.4 1340.8 1336.89 11.84 1359.2 1311.1
142000 19750800 60 1336.14 27.34 1390.9 1286.4 1402.42 28.69 1458.2 1348.5 1416.98 28.6 1470.9 1361.9 1385.17 28.16 1438.6 1332.3
143000 19751400 60 1329.63 17.76 1369.7 1294 1394.11 19.14 1433.7 1356.3 1409.68 19.13 1449.2 1374.3 1377.81 18.62 1416.9 1341.5
144000 19752000 60 1326.64 18.05 1363.6 1288.2 1391.62 18.69 1430.5 1350.2 1406.33 19.66 1447.3 1364.9 1374.87 18.72 1413.8 1336.4
145000 19752600 60 1320.74 23.07 1360.4 1264.8 1384.76 23.34 1421.3 1329.7 1398.06 23.51 1434.3 1342 1367.85 23.2 1405.2 1312.3
150000 19753200 60 1327.77 32.13 1397 1262.7 1391.94 32.96 1459.6 1328.1 1406.67 33.47 1477.2 1341.8 1375.46 32.8 1444 1310.9
141000 19750200 15 50.01 0.08 50.13 49.88 50.01 0.08 50.13 49.88 50.01 0.08 50.13 49.88 0.57 0.25 0.89 0
142000 19750800 60 49.97 0.08 50.13 49.88 49.97 0.08 50.13 49.88 49.97 0.08 50.13 49.88 0.65 1.14 6.61 0
143000 19751400 60 49.99 0.09 50.13 49.88 49.99 0.09 50.13 49.88 49.99 0.09 50.13 49.88 0.51 0.2 0.89 0
144000 19752000 60 49.95 0.09 50.13 49.75 49.95 0.09 50.13 49.75 49.95 0.09 50.13 49.75 0.45 0.26 0.78 0
145000 19752600 60 49.96 0.08 50.13 49.75 49.96 0.08 50.13 49.75 49.96 0.08 50.13 49.75 0.68 1.29 6.33 0
150000 19753200 60 49.98 0.09 50.13 49.88 49.98 0.09 50.13 49.88 49.98 0.09 50.13 49.88 0.61 1.13 6.5 0
141000 19750200 15 0.66 0.32 1.51 0 0.72 0.14 1.08 0.57 0.68 0.58 1.28 0 1.06 0.48 1.86 0
142000 19750800 60 1.09 1.51 7.13 0 0.74 0.25 1.62 0 0.76 0.57 1.59 0 1.45 1.83 7.34 0
143000 19751400 60 0.71 0.76 6.09 0.44 0.61 0.13 1.12 0.45 0.87 0.39 1.25 0 1.12 1.04 6.5 0
144000 19752000 60 0.66 0.77 6.17 0 0.64 0.28 1.54 0 0.77 0.48 1.41 0 1.07 1.29 6.72 0
145000 19752600 60 0.71 1.05 6.17 0 0.57 0.21 1.34 0 0.63 0.49 1.32 0 1.18 1.65 6.55 0
150000 19753200 60 0.84 1.38 7.14 0 0.6 0.26 1.64 0 0.69 0.5 1.58 0 1.16 1.6 7.34 0
141000 19750200 15 0.98 0.3 1.3 0
142000 19750800 60 1.21 0.98 6.4 0
143000 19751400 60 0.99 0.16 1.33 0.59
144000 19752000 60 0.86 0.28 1.27 0
145000 19752600 60 0.79 0.34 1.24 0
150000 19753200 60 1.05 1.01 6.29 0
    
```

Table 3

Table (4) The Diurnal file (10-minute average) generated by PM300STA.EXE program

0	1413	12390.9	148.59	12899	12250	12966.8	145.304	13288	12607	12484.7	144.235	12775	12140	21965.3	251.181	22470	21370
10	1389	12594.4	145.778	12876	12284	12957.5	144.981	13259	12643	12475.3	143.090	12761	12180	21949.1	250.021	22450	21400
20	1440	12597.8	139.352	12865	12297	12960.9	137.545	13253	12670	12478.8	136.114	12746	12196	21955.1	237.317	22420	21470
30	1440	12591.3	128.736	12866	12214	12963	127.597	13250	12591	12481.9	126.258	12763	12118	21960.3	220.328	22480	21330
40	1440	12594.4	124.796	12864	12227	12967	122.541	13254	12595	12485.8	122.137	12761	12127	21966.8	212.688	22450	21340
50	1424	12611.8	129.490	12879	12236	12981.4	128.032	13250	12613	12500.8	127.488	12780	12153	21995.1	221.748	22440	21370
100	1394	12599.2	128.632	12837	12217	12967.4	126.423	13269	12617	12490.8	126.199	12729	12147	21974.2	219.423	22390	21360
110	1441	12596	131.259	12858	12216	12954.1	128.123	13227	12619	12481.8	128.778	12738	12147	21951.8	223.457	22400	21370
120	1500	12601.5	139.325	12922	12209	12967.4	136.746	13288	12615	12495.8	136.904	12804	12140	21976.5	237.758	22510	21350
130	1500	12613.3	137.964	12924	12204	12980.1	134.65	13287	12680	12509.8	135.273	12903	12188	21998.1	234.853	22510	21420
140	1500	12619.7	140.178	12942	12229	12986.7	136.427	13296	12638	12515.1	137.108	12819	12178	22009.3	238.299	22540	21400
150	1500	12625.3	137.905	12921	12251	12990.3	132.886	13282	12681	12520.7	134.894	12906	12197	22018	233.579	22520	21440
200	1500	12607.8	143.058	12890	12261	12970.9	138.447	13253	12663	12505	140.147	12774	12189	21987.4	242.991	22480	21440
210	1580	12598.1	143.574	12843	12239	12962	138.457	13195	12689	12496.5	140.115	12727	12188	21971.8	242.986	22380	21420
220	1580	12600.7	139.305	12841	12273	12963.3	136.194	13209	12671	12499.2	136.682	12735	12209	21975.8	237.225	22390	21450
230	1580	12611.8	139.887	12885	12239	12974.8	136.278	13208	12601	12509.8	137.001	12739	12196	21994.8	237.828	22400	21370
240	1580	12620	144.806	12907	12259	12982.9	141.432	13260	12614	12519.9	141.828	12778	12170	22009	246.508	22470	21400
250	1536	12631.2	138.393	12901	12312	12990.2	135.532	13235	12683	12528.5	135.995	12775	12218	22027.6	238.05	22480	21490
300	1500	12647	137.057	12939	12324	13009.5	134.53	13248	12686	12544.5	135.248	12787	12241	22055.2	234.423	22500	21520
310	1500	12652.7	140.472	12905	12333	13014.9	137.377	13241	12698	12550.1	138.025	12772	12248	22065	239.553	22450	21540
320	1500	12658.3	142.244	12917	12319	13019.8	138.588	13273	12697	12554.9	139.24	12780	12233	22072.5	241.989	22480	21510
330	1500	12658.5	141.858	12938	12315	13019.8	136.705	13273	12691	12554.5	138.087	12796	12225	22072.4	239.79	22510	21500
340	1500	12654.5	138.378	12928	12319	13018.8	133.332	13309	12713	12533	135.095	12821	12232	22069.9	234.288	22550	21510
350	1500	12657.1	138.758	12941	12324	13020	135.878	13319	12688	12554.7	136.319	12827	12243	22073	238.8	22580	21530
400	1500	12655.8	141.306	12951	12340	13019.4	138.796	13320	12708	12533.8	138.842	12835	12254	22071.4	240.078	22570	21540
410	1500	12664.8	148.217	12967	12332	13028.9	143.412	13334	12707	12582.7	145.491	12846	12250	22087.3	251.826	22590	21530
420	1500	12672	151.482	12991	12371	13035.9	147.529	13348	12735	12570.2	148.734	12870	12285	22099.7	257.891	22630	21600
430	1500	12673.2	152.591	12983	12379	13037.8	148.79	13347	12741	12571.4	149.755	12868	12286	22102.3	259.887	22620	21600
440	1440	12672.2	151.309	13004	12373	13037.4	147.405	13365	12745	12570.5	148.597	12876	12283	22100.9	257.778	22640	21600
450	1441	12674.8	154.549	13021	12378	13039.8	151.177	13375	12741	12572	152.275	12895	12284	22104.8	264.002	22670	21610
500	1440	12675.3	149.904	13045	12407	13041.1	147.838	13408	12751	12573.1	148.13	12936	12316	22108.4	258.873	22740	21650
510	1440	12675.5	148.221	13044	12409	13041.1	144.319	13405	12777	12573.4	145.800	12925	12317	22108.7	252.495	22730	21690
520	1440	12681.8	148.481	13067	12438	13047	144.485	13414	12800	12579.3	145.401	12958	12329	22117	252.497	22760	21700
530	1440	12687	144.307	13039	12441	13053	139.884	13397	12815	12585.8	141.432	12919	12344	22127.2	245.345	22720	21720
540	1441	12688.9	147.749	13033	12399	13064.4	143.847	13398	12792	12596.7	145.003	12917	12323	22147.1	251.671	22710	21670
550	1500	12693.8	153.898	13049	12421	13068.8	148.578	13408	12788	12592	150.871	12926	12326	22158.1	261.029	22730	21690
600	1500	12688.2	145.917	13035	12445	13062.1	141.189	13374	12808	12596.3	143.395	12910	12349	22145	248.098	22890	21720
610	1500	12688.9	148.101	13011	12402	13060.2	144.002	13359	12754	12594.8	148.354	12890	12303	22142.3	252.582	22850	21840
620	1500	12700.8	152.974	13030	12380	13065.1	148.226	13368	12745	12598.2	150.488	12900	12287	22149.5	263.332	22880	21810
630	1500	12710.8	155.348	13032	12379	13075.8	150.751	13380	12753	12608.8	152.508	12908	12297	22167.4	264.443	22890	21820
640	1500	12718.7	160.727	13043	12417	13081.2	155.123	13410	12779	12615	157.47	12930	12329	22177.7	272.888	22730	21890
650	1500	12717.5	165.706	13045	12409	13082.8	161.478	13397	12779	12618.3	163.35	12926	12312	22179.8	282.888	22720	21870
700	1500	12705.8	173.418	13084	12388	13070	168.198	13433	12717	12604.8	170.318	12957	12287	22158.8	294.995	22780	21570
710	1500	12691.9	178.331	13078	12358	13057.2	172.978	13430	12725	12591.4	174.79	12951	12257	22135.8	300.471	22770	21580
720	1500	12679.2	180.139	13087	12352	13044	174.434	13422	12719	12577.8	176.578	12953	12258	22112.8	308.352	22760	21530
730	1440	12674.7	180.897	13084	12328	13039.8	177.182	13421	12702	12573.2	178.028	12943	12232	22105.5	309.189	22750	21520
740	1440	12659.8	182.897	13058	12287	13024.8	178.465	13407	12683	12558.8	179.361	12940	12202	22079.7	311.741	22740	21450
750	1440	12645.9	181.893	13055	12280	13030.8	176.305	13403	12670	12543.1	178.371	12941	12181	22054.2	309.271	22730	21440
800	1440	12618.9	184.858	13027	12248	12980.8	180.304	13354	12652	12514.8	181.01	12890	12171	22004	314.715	22670	21410
810	1381	12585.9	186.242	12995	12258	12949.9	183.82	13347	12630	12480.8	180.884	12875	12156	21950.5	319.358	22630	21400
820	1380	12554.9	187.885	12982	12209	12919.4	184.82	13310	12603	12453.8	185.171	12844	12139	21897.7	321.802	22590	21350
830	1380	12532	188.891	12912	12229	12896.5	187.983	13288	12589	12430.1	186.892	12796	12135	21857.8	325.053	22490	21350
840	1320	12517.5	189.933	12891	12189	12882.7	189.727	13283	12587	12415.7	188.307	12781	12092	21832.9	327.858	22470	21270
850	1320	12504	188.498	12878	12218	12869.8	184.95	13229	12573	12400.1	188.585	12758	12121	21808.2	319.991	22420	21320
900	1288	12503.7	185.777	12850	12187	12870.3	184.358	13207	12541	12399.5	188.372	12735	12087	21808.8	319.022	22380	21280
910	1320	12511.4	195.87	12857	12182	12878	193.577	13218	12538	12405.4	190.315	12738	12049	21819.7	308.174	22400	21230
920	1280	12520.5	184.539	12820	12147	12889.9	183.036	13191	12520	12417.5	182.408	12725	12036	21841.8	317.2	22350	21200
930	1280	12521.2	177.839	12778	12154	12886.7	175.343	13149	12535	12415.8	175.177	12684	12039	21837.3	304.828	22270	21200
940	1280	12524.8	177.278	12800	12159	12890.5	178.582	13168	12539	12419.2	175.17	12686	12048	21843.5	305.078	22310	21220
950	1280	12533.8	180.813	12883	12145	12899.8	179.137	13238	12512	12428.3	177.811	12761	12031	21859.8	310.078	22440	21190
1000	1280	12538	183.815	12885	12143	12903	182.137	13240	12529	12431.8	181.199	12762	12042	21865.7	315.849	22450	21210
1010	1280	12531.8	185.778	12879	12148	12898.3	183.832	13229	12534	12425.1	180.202	12757	12044	21854.4	318.857	22430	21210
1020	1																

Table (5) The Average Wind Speed (Daily – Hourly) during measurement period from 16/12/2005 to 15/01/2006

Day Hours	Days															
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
00:00	4.0	4.8	3.5	1.8	3.9	10.9	12.4	7.5	4.2	5.2	4.3	8.3	8.4	2.2	11.1	9.0
01:00	3.9	6.0	2.4	3.1	2.9	10.7	12.3	7.5	5.1	3.0	4.6	6.5	7.5	2.6	11.7	10.0
02:00	3.6	7.1	2.3	4.3	2.7	10.4	11.2	7.6	7.3	4.6	4.5	6.9	7.4	4.6	11.3	8.6
03:00	4.5	8.2	1.7	2.7	3.8	10.0	10.0	4.7	6.0	6.0	4.3	8.5	8.5	3.0	14.3	4.5
04:00	5.0	7.1	1.4	3.0	3.6	9.1	9.9	4.0	5.0	3.0	4.4	8.5	4.9	2.4	13.9	4.8
05:00	7.0	7.9	2.1	2.3	3.5	9.8	8.7	2.7	4.7	3.5	3.7	7.1	3.4	1.2	12.6	6.3
06:00	8.0	8.8	2.4	1.9	3.7	9.6	8.0	3.5	5.2	5.6	2.9	7.7	3.4	1.8	9.0	4.5
07:00	6.1	6.9	2.3	2.4	1.9	9.9	8.0	3.3	6.1	4.8	3.2	8.0	3.1	2.0	7.7	3.3
08:00	6.0	7.1	1.9	2.2	3.0	10.4	9.9	4.8	6.8	3.8	3.5	7.7	5.7	4.4	9.8	1.7
09:00	5.5	6.1	1.6	1.7	7.9	10.7	10.5	7.1	7.8	4.3	4.6	7.9	8.5	8.4	11.1	3.3
10:00	6.2	5.6	2.3	3.5	8.1	10.6	10.5	8.0	7.9	4.1	5.1	8.9	9.2	7.0	10.8	3.1
11:00	7.8	6.0	1.9	3.4	8.8	10.7	10.6	8.4	8.6	3.8	6.6	8.9	8.8	7.2	10.9	4.8
12:00	9.4	6.4	3.3	5.0	9.0	10.5	10.5	8.4	9.2	5.0	7.0	9.2	9.0	8.0	10.3	5.7
13:00	8.4	5.8	4.2	6.2	9.4	10.6	10.1	7.3	9.4	7.4	6.9	7.7	8.4	9.9	9.6	5.4
14:00	6.1	5.7	5.7	5.7	10.2	11.4	10.1	6.9	8.0	7.4	6.5	7.7	7.9	11.2	9.1	5.4
15:00	6.6	5.2	4.7	4.5	10.2	12.4	9.7	5.8	5.8	7.8	7.2	8.8	7.6	11.5	9.9	5.9
16:00	4.5	3.3	4.1	3.4	9.9	12.5	9.0	5.1	5.4	8.8	6.5	8.4	7.2	10.9	11.1	7.4
17:00	3.8	1.6	3.4	2.5	9.2	12.0	8.9	3.4	5.9	6.3	7.1	8.2	8.0	11.1	11.1	9.3
18:00	3.9	1.1	2.3	2.1	10.2	12.4	9.6	2.0	4.5	5.9	7.4	7.7	8.0	10.1	10.7	9.7
19:00	3.7	2.8	2.1	2.5	10.9	12.5	9.2	2.1	4.1	5.8	7.9	8.8	8.0	9.2	11.7	10.0
20:00	3.9	4.3	2.1	3.1	10.9	13.0	8.2	3.7	3.7	4.6	9.7	9.9	5.7	9.8	12.8	10.6
21:00	4.9	4.7	1.1	3.8	10.5	13.0	8.3	4.3	3.9	5.1	10.3	8.9	5.2	10.5	12.0	10.0
22:00	4.0	3.2	1.3	5.4	9.5	13.1	8.5	5.8	3.8	3.4	10.6	9.1	3.8	11.1	9.2	8.3
23:00	6.2	3.4	1.5	5.1	10.8	12.8	8.4	4.5	4.4	2.8	9.6	8.0	1.9	9.8	8.3	7.9
AVG_{day}	5.5	5.4	2.6	3.4	7.3	11.2	9.7	5.3	6.0	5.1	6.2	8.2	6.6	7.1	10.8	6.6

Day Hours	Days																AVG _{hour}
	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31		
00:00	7.7	11.3	11.8	7.4	1.7	10.4	12.4	8.6	6.0	9.3	8.3	5.3	6.5	2.1	5.4	7.0	
01:00	9.9	10.9	13.0	4.8	3.0	10.9	11.9	8.3	5.8	8.9	5.2	4.7	6.8	2.9	3.7	6.7	
02:00	4.7	6.9	12.9	2.6	1.9	12.6	12.0	6.0	5.5	8.5	1.5	5.7	6.4	2.7	2.4	6.3	
03:00	4.7	4.2	12.0	4.2	1.2	11.2	11.8	3.0	5.9	7.0	2.6	5.7	6.1	1.8	3.5	6.0	
04:00	5.2	2.5	12.7	4.4	2.1	10.6	10.7	2.6	5.5	4.5	3.4	5.2	5.1	2.8	4.1	5.6	
05:00	3.7	9.0	12.0	2.3	2.4	10.6	10.4	2.9	4.2	4.5	4.1	5.2	3.9	3.1	3.1	5.4	
06:00	5.3	11.9	11.2	2.2	1.9	10.4	10.7	3.8	5.2	5.0	4.3	5.0	3.5	3.9	2.5	5.6	
07:00	3.8	11.8	11.1	3.4	1.1	12.1	9.0	3.2	4.8	4.2	5.6	4.8	4.1	4.3	2.3	5.4	
08:00	5.8	12.9	11.6	2.9	1.0	11.8	3.7	4.7	5.6	4.6	4.4	3.7	3.4	3.1	2.1	5.6	
09:00	7.1	11.8	11.4	1.2	1.4	12.2	7.6	5.1	6.3	5.4	3.0	3.3	3.1	2.4	3	6.3	
10:00	6.8	11.7	11.1	3.2	1.9	11.9	10.2	7.0	7.0	5.3	1.6	2.3	6.8	2.2	5.9	6.8	
11:00	6.9	12.6	11.0	2.8	2.2	11.7	11.4	8.2	8.2	3.9	3.2	1.8	8.7	2.7	7.3	7.2	
12:00	7.0	13.0	9.9	2.2	2.3	12.0	11.8	9.5	8.3	3.4	5.4	2.6	9.4	5.8	7.6	7.7	
13:00	6.7	13.2	9.1	2.8	2.9	12.1	11.7	8.8	9.0	2.6	4.7	2.3	9.7	7.1	8.5	7.8	
14:00	5.9	13.4	9.1	3.7	2.7	12.4	12.0	8.5	8.5	4.6	2.3	3.5	9.6	5.8	7.8	7.6	
15:00	5.7	13.1	9.2	3.3	4.3	12.9	11.2	7.4	8.0	5.0	2.9	3.7	8.9	5	6.7	7.5	
16:00	6.1	13.2	9.5	4.7	5.2	12.6	10.6	5.3	7.1	5.5	4.2	2.6	7.8	1.7	7.4	7.1	
17:00	7.1	13.4	8.9	6.7	7.3	13.0	10.5	3.4	6.0	5.6	4.4	2.2	6.8	1.5	6.8	6.9	
18:00	8.6	14.7	9.2	6.4	8.6	12.9	10.0	2.7	7.2	5.8	4.6	1.9	7.0	4.2	6.4	6.9	
19:00	9.3	15.6	8.5	4.4	10.5	13.6	9.9	5.7	7.4	6.6	4.0	2.7	9.6	4.8	4.6	7.3	
20:00	9.4	15.1	9.7	2.4	12.8	13.5	10.0	8.2	7.3	7.3	5.1	3.8	7.6	4.3	4.5	7.5	
21:00	9.7	14.1	11.2	2.1	13.4	14.1	8.3	7.2	8.6	9.5	6.3	5.7	7.0	4.9	4.5	7.8	
22:00	10.1	13.0	10.6	1.4	11.6	13.6	8.9	9.5	10.1	7.8	5.1	6.6	6.1	4	4.6	7.5	
23:00	11.3	11.9	10.7	1.2	10.5	13.1	9.0	8.9	8.6	7.3	3.6	6.2	4.3	5.7	4.1	7.1	
AVG_{day}	7.0	11.7	10.7	3.4	4.7	12.2	10.2	6.2	6.9	5.9	4.2	4.0	6.6	3.7	4.9	6.8	

Hourly Average Daily Average Period Average

Table (5)